

For more information about this Water Quality Report, please contact our Water Control Center at 703-228-6555.

You may also consult the County's website at [www.arlingtonva.us](http://www.arlingtonva.us) and the U.S. Environmental Protection Agency (EPA)'s website at [www.epa.gov/safewater](http://www.epa.gov/safewater)

Electronic copies of this report are available online at [www.arlingtonva.us/departments/environmentalservices/uepd/wquality/environmentalservicesarlwq.aspx](http://www.arlingtonva.us/departments/environmentalservices/uepd/wquality/environmentalservicesarlwq.aspx)

Arlington County Department of Environmental Services  
Water, Sewer and Streets Bureau  
4200 South 28th Street  
Arlington, VA 22206

**Important Water Quality Information Enclosed**



## Department of Environmental Services

Water, Sewer and Streets Bureau

# 2013 Annual Water Quality Report

---

**WILLSTON REPORT**

---



**T**he Arlington County Water, Sewer and Streets Bureau is committed to providing residents with a reliable supply of high quality drinking water. We test County water using sophisticated equipment and advanced procedures and our water meets all state and federal standards for water quality. This annual "Consumer Confidence Report," required by the Safe Drinking Water Act (SDWA), tells you where your water comes from, what our tests show about it, and other things you should know about drinking water.

**El informe contiene información importante sobre la calidad del agua en su comunidad. Tradúzca lo ó hable con alguien que lo entienda bien.**

#### NOTICE ABOUT PERCHLORATE

Perchlorate is a naturally occurring as well as man-made compound. Its presence in drinking water is currently unregulated and utilities are not required to monitor for it. The Washington Aqueduct has been voluntarily monitoring for perchlorate since 2002. The EPA initially established a reference dose of 24.5 parts per billion (ppb) for perchlorate and beginning in 2009 has proposed an interim health advisory of 15 ppb. A reference dose is a scientific estimate of daily exposure level that is not expected to cause adverse health effects in humans. The reference dose concentration was used in EPA's efforts to address perchlorate in drinking water and to establish the interim health advisory.

The source and treated water samples collected in 2013 from the Dalecarlia and McMillian treatment plants showed only trace amounts of perchlorate. The highest level detected was 1.4 ppb. If you have special health concerns, you may want to get additional information from the EPA at <http://water.epa.gov/drink/contaminants/unregulated/perchlorate.cfm> or contact the EPA's Safe Drinking Water Hotline at 800-426-4791.

## WHERE DOES OUR WATER COME FROM?

Arlington County purchases its water from the Washington Aqueduct Division of the Army Corps of Engineers. The Washington Aqueduct operates two water treatment plants in the District of Columbia. The plants treat water from a surface water source, the Potomac River. Arlington's water is treated at the Dalecarlia Treatment Plant located on MacArthur Boulevard in Northwest Washington. The Interstate Commission on the Potomac River Basin conducted a Source Water Assessment of the Potomac River watershed in April 2002. The assessment identified urban runoff, toxic spills, agriculture and inadequate wastewater treatment as potential contamination sources to the water supply. Contact the Interstate Commission on the Potomac River Basin at (301) 984-1908 for more information. For additional source water information, you may also read the Arlington Water System 2013 Annual Water Quality Report at <http://water.arlingtonva.us/water/water-quality-reports/> Arlington County maintains water quality assurance through our regular water distribution and storage evaluations and routine water sampling analysis.

## WHAT ELSE SHOULD I KNOW?

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More

information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

## LEAD IN DRINKING WATER

The U.S. EPA finalized Lead and Copper Rule Short-Term Regulatory Revisions and Clarifications in October 2007 with one of its goals being to improve customer awareness. Hundreds of water samples have been taken throughout Arlington County to determine the lead concentration in our water. Historically these concentrations have been below the action level for lead. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Arlington County is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead)

#### Property Managers of Multiple Unit Dwellings:

Please share this information with all other people who drink this water, especially those who may not have received this Water Quality Report directly. You can do this by posting this notice in a public place or distributing copies by hand or mail. If additional copies are needed, contact our Water Control Center at 703-228-6555.

## IMPORTANT HEALTH INFORMATION

Source water is tested for *Cryptosporidium*, a parasite that has caused outbreaks of intestinal disease in the U.S. and overseas. It is common in surface water, to kill, and even the best water system will contain some live parasites. The U.S. Environmental Protection Agency (EPA) is working to improve the control of microbial pathogens, namely the protozoan *Cryptosporidium* in drinking water. The Potomac River source was monitored at Great Falls for *Cryptosporidium* during 2013 and there were no detects. No precaution about County drinking water is currently necessary for the general public.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.



U.S. Environmental Protection Agency

## HOW TO READ THIS TABLE

It's easy! Our water is tested to assure that it is safe and healthy. The results of tests performed in 2013 or the most recent testing available are presented in the table. Footnotes below the chart are provided to explain important details.

The column marked **Goal** shows the Maximum Contaminant Level Goal or MCLG. This is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

The column marked **Maximum Allowed** is the Maximum Contaminant Level or MCL. This is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

The column marked **Detected Level** shows the results observed in our water during the most recent round of testing.

**Source of Substance** provides an explanation of the typical natural or man-made origins of the contaminant.

**Action Level (AL)** is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Treatment Technique (TT)** is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Residual Disinfectant Level (MRDL)** is the highest level of a residual disinfectant that is allowed in drinking water.

**Maximum Residual Disinfectant Level Goal (MRDLG)** is the level of a residual disinfectant below which there is no known or expected risk to health. MRDLGs allow for a margin of safety.



**Non-detects (ND)**—lab analysis indicates that the contaminant is not present.

**Nephelometric Turbidity Unit (NTU)**—nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Parts per million (ppm)** or Milligrams per liter (mg/l)—one part per million corresponds to one minute in two years, or a single penny in \$10,000.

**Parts per billion (ppb)**—one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)**—one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Picocuries per liter (pCi/l)**—picocuries per liter is a measure of the radioactivity in water.

# SUMMARY OF 2013 WATER QUALITY DATA<sup>1</sup>

FINISHED WATER CHARACTERISTICS, SOURCE MONITORING							
Substance	Date Tested	Unit	Goal (MCLG)	Maximum Allowed (MCL)	Detected Level	Range of Levels Detected	Source of Substance
Antimony	2013	ppb	6	6	0.1	ND-0.1	Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.
Arsenic	2013	ppb	0	10	0.8	ND-0.8	Run off from orchards, glass and electronic produced waste <sup>2</sup>
Atrazine	2013	ppb	3	3	0.07	ND-0.07	Runoff from herbicide used on row crops
Barium	2013	ppm	2	2	0.04	0.02-0.04	Runoff from herbicide used on row crops
Beta/photon Emitters <sup>3</sup>	2011	pCi/L	0	50 <sup>4</sup>	3.2	ND-3.2	Discharge of drilling waste from metal refineries <sup>2</sup>
Chromium	2013	ppb	100	100	4	ND-4	Discharge from steel and pulp mills <sup>2</sup>
Combined Radium 226/228 <sup>3</sup>	2011	pCi/L	0	5	1.2	ND-1.2	Erosion of natural deposits or products
Dalapon	2013	ppb	200	200	1.2	ND-1.2	Runoff from herbicide used on the right of way
Fluoride	2013	ppm	4.0	4.0	0.9	0.3-0.9	Water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen)	2013	ppm	10	10	3	0.5-3	Runoff from fertilizer use; leaching from septic tanks, sewage
Nitrite (as Nitrogen)	2013	ppm	1	1	0.02	ND-0.02	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits
Selenium	2013	ppb	50	50	1	ND-1	Discharge from petroleum; mines and metal refineries
Total Organic Carbon (TOC)	2013	ppm	n/a	TT	Running annual average removal ratio is required to be greater than 1.0. Removal ratio actually achieved ≥ 1.22.		Naturally present in the environment
Turbidity <sup>5</sup>	2013	NTU	n/a	TT	0.09 = highest single measurement. Lowest monthly percentage of samples meeting turbidity requirements = 100%.		Soil runoff
Uranium	2013	ppb	0	30	0.1	ND-0.1	<sup>2</sup>

## FINISHED WATER CHARACTERISTICS, ARLINGTON COUNTY DISTRIBUTION SYSTEM MONITORING

Copper <sup>6</sup>	2013	ppm	1.3	AL-1.3	0.03	0.01-0.07	Leaching from wood preservatives; corrosion of household plumbing <sup>2</sup>
Lead <sup>7</sup>	2013	ppb	0	AL-15	1	0.17-3.5	Runoff from fertilizer use; leaching from septic tanks; corrosion of household plumbing <sup>2</sup>
Total Coliform <sup>8</sup>	2013	n/a	0	1	0	ND	Naturally present in the environment
Chloramines <sup>9</sup>	2013	ppm	(MRDLG) 4	(MRDL) 4	2.6	1.1-3.2	Water additive used to control microbes
TTHM <sup>9</sup>	2013	ppb	n/a	80	42	18-61	By-product of drinking water chlorination
HAA5 <sup>9</sup>	2013	ppb	n/a	60	31	15-40	By-product of drinking water chlorination

## AVERAGE LEVELS OF COMPOUNDS IN WILLSTON DRINKING WATER

Calcium	39 mg/L	Magnesium	7 mg/L
Chloramine Residual	2.6 ppm	Nickel	2.1 ppb
Chloride	33 mg/L	pH	7.8
Fluoride	0.7 ppm	Sodium <sup>1</sup>	22 ppm
Hardness	128 mg/L or 7.5 grains/gal	Sulfate	50 mg/L

The Willson Area Distribution System had no positive samples out of 24 samples collected for total coliform in the calendar year 2013. There were no detections of E. coli in any of the monthly samples during the calendar year 2013.

\* Although sodium is not regulated by an MCL, the EPA's Fall 2009 Drinking Water Advisory Table identifies 20 mg/L as a health-based value for an individual on a 500 mg/day restricted sodium diet.

1 All test results are from 2013 unless otherwise noted.

2 Erosion of natural deposits or products

3 Triennial radionuclide monitoring was performed in 2011.

4 The MCL for beta and photon emitters is 4 mrem/year and EPA considers 50 pCi/L to be the level of concern for beta/photon emitters. Because the beta particle results were below 50 pCi/L, no testing for individual beta particle constituents was required.

5 Turbidity is the measure of cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of the filtration process. The turbidity level of filtered water shall be less than or equal to 0.3 NTU in at least 95% of the measurements taken each month, and shall at no time exceed 1 NTU. One hundred percent (100%) of the samples tested were below the Treatment Technique Level of 0.30 NTU.

6 The Detected Level represents the 90th percentile value. None of the 11 samples tested for copper exceeded the current Action Level of 1.3 ppm.

7 The Detected Level represents the 90th percentile value. None of the 11 samples tested for lead exceeded the current Action Level of 15 ppb.

8 The Detected Level represents the highest monthly number of positive results.

9 The Detected Level represents the highest running annual compliance average during the calendar year.